Month	Nov-13						
EPL Licence	20241	Project	NSRU Project				
EPL weblink	ttp://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=32705&SYSUID=1&LICID=20241						
Specific EPL licence monitoring conditions for							
noise	Condition E1 Requirements for Works permissible under L3.4, L3.5 and L3.6						

Monitoring location	Number of	Attended or	Event based monitoring	Parameter eg Tag	min value dB(A) for month	max value dR(Δ) for	goals / targets dB(A)	Comment
Monitoring location	times	continuous monitoring		(15min)	min value ab(A) for monen	month	godis / targets ab(A)	Comment
	monitored	continuous monitoring	(1714)	(1311111)		monun		
	during the							
	month							
2A Hamilton Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	65.7	65.7	74	
2A Hamilton Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	57	57	66	
19-21 George Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	60	60	82	
19-21 George Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	56.8	56.8	71	
8 King street, Concord West	1	Attended	Υ	Laeq (15 min)	70.6	70.6	72	
123 Queen Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	64.5	64.5	66	
121 Queen Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	63.5	63.5	64	
67 Queen Street, North Strathfield	2	Attended	Υ	Laeq (15 min)	73.4	73.4	65	Site external influence - road traffic
								(cars, concrete truck); note original
								respite categories are not altered -
								levels still within original respite
								categories; No complaint received
31 Queen Street, North Strathfield	2	Attended	Υ	Laeq (15 min)	60	60.6	73	
31 Queen Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	63.1	63.1	70	
33 Queen Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	58.6	58.6	70	Complaint received; No exceedance and
								levels well under predicted levels
207 Queen Street, Concord West	1	Attended	Υ	Laeq (15 min)	62	62	71	
14 Harrison Ave, Concord West	1	Attended	Υ	Laeq (15 min)	65.6	65.6	60	Note: Monitoring conducted at
								fenceline and house setback from
								fence.No complaint received; Lighting
								tower location to be reviewed
241 Queent Street, Concord West	1	Attended	Υ	Laeq (15 min)	62	62	72	
6 King Street, Concord West	2	Attended	Υ	Laeq (15 min)	67.3	67.7	70	
25 Queen Street, North Strathfield	1	Attended	Υ	Laeq (15 min)	58.5	58.5	70	
133 Queen Street, Concord West	2	Attended	Υ	Laeq (15 min)	63	66	65	Minor exceedance; Site external
								influence - road traffic; note original
								respite categories are not altered -
								levels still within original respite
								categories; No complaint received
19-24 Thorpewood, 9 Thorpe Ave, Liberty Grove,	1	Attended	Υ	Laeq (15 min)	52.9	52.9	71	
Concord West								
15 Queen Street, North Strathfield	1	Attended		Laeq (15 min)	72	72	72	
8 King Street, Concord West	1	Attended		Laeq (15 min)		58.4	68	
53 Princess Ave, North Strathfield	1	Attended		Laeq (15 min)	59.7	59.7	75	
94 Queen Street, Concord West	1	Attended	Υ	Laeq (15 min)	56.8	56.8	58	

VIBRATION Monitoring Data - Monthly Summary							
Month	Nov-13						
EPL Licence	20241	Project	NSRU				
EPL weblink	http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=32705&SYSUID=1&LICID=20241						
Specific EPL licence							
monitoring conditions for							
vibration	Condition E1 Requirements for Works permissible under L3.4, L3.5 and L3.6						

	number of times		Parameter eg. Peak	units of	minimum	maximum	allowable	percentile reporting	
	monitored during the	event based	particle velocity PPV,	measurement	value for	value for	maximum	period (1 year, 1 month,	Percentile limit* (eg.
Monitoring location	month	monitoring (Y/N)	Airblast overpressure	(mm/s, dBL)	month	month	limit	etc)	90th%ile)
Arnotts Building	1	N	PPV	mm/s	0.349	2.83	7.5	N/A	N/A