WATER Monitoring Data - Monthly Summary								
Month	**Apr-14**							
EPL Licence	**20079**			**Project**	**SOH VAPS**			
EPL weblink	http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&SYSUID=1&LICID=20079							
Specific EPL licence monitoring conditions for water	**Condition L2 - Concentration Limits** **Condition M2 - Requirement to monitor concentration of pollutants discharged**							
Monitoring location	**Number of times monitored during the month**	**Event based monitoring (Y/N)**	**Parameter measured**	**Units of measurement (mg/L, NTU, pH)**	**Minimum value for month**	**Maximum value for month**	**Allowable minimum limit**	**Allowable maximum limit**
Water Treatment Plant Holding Tank	2	N	pH	pH Units	6.5	6.8	6.5	8.5
Water Treatment Plant Holding Tank	2	N	Total Suspended Solids	mg/L	< 5	13	0	50
Water Treatment Plant Holding Tank	2	N	Oil and Grease	mg/L	< 5	< 5	0	10
Water Treatment Plant Holding Tank	2	N	Copper	ug/L	< 1	2	0	10
Water Treatment Plant Holding Tank	2	N	Iron	ug/L	220	290	0	800
Water Treatment Plant Holding Tank	2	N	Lead	ug/L	< 1	< 1	0	22
Water Treatment Plant Holding Tank	2	N	Manganese	ug/L	700	1900	0	2000