WATER Monitoring Data - Monthly Summary			
Month	**July**		
EPL Licence	**20079**	**Project**	**SOH VAPS**
EPL weblink	http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&SYSUID=1&LICID=20079		
Specific EPL licence monitoring conditions for water	**Condition L2 - Concentration Limits** **Condition M2 - Requirement to monitor concentration of pollutants discharged**		

Monitoring location	Number of times monitored during the month	Event based monitoring (Y/N)	Parameter measured	Units of measurement (mg/L, NTU, pH)	Minimum value for month	Maximum value for month	Allowable minimum limit	Allowable maximum limit
Water Treatment Plant Holding Tank	3	Y	pH	pH Units	7.3	7.5	6.5	8.5
	3	Y	Total Suspended Solids	mg/L	<5	<5	0	50
	3	Y	Oil and Grease	mg/L	<5	<5	0	10
	3	Y	Copper	ug/L	2	5	0	10
	3	Y	Iron	ug/L	30	160	0	800
	3	Y	Lead	ug/L	<1	<1	0	22
	3	Y	Manganese	ug/L	20	230	0	2000