

**WATER Monitoring Data - Monthly Summary**

WATER Monitoring Data - Monthly Summary								
Month	Aug-14							
EPL Licence	20079	Project		SOH VAPS				
EPL weblink	<a href="http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&amp;SYSUID=1&amp;LICID=20079">http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&amp;SYSUID=1&amp;LICID=20079</a>							
Specific EPL licence monitoring conditions for water	Condition L2 - Concentration Limits Condition M2 - Requirement to monitor concentration of pollutants discharged							
Monitoring location	Number of times monitored during the month	Event based monitoring (Y/N)	Parameter measured	Units of measurement (mg/L, NTU, pH)	Minimum value for month	Maximum value for month	Allowable minimum limit	Allowable maximum limit
Water Treatment Plant Holding Tank	2	Y	pH	pH Units	7	7.1	6.5	8.5
	2	Y	Total Suspended Solids	mg/L	7	14	0	50
	2	Y	Oil and Grease	mg/L	< 5	6	0	10
	2	Y	Copper	ug/L	< 1	< 1	0	10
	2	Y	Iron	ug/L	40	100	0	800
	2	Y	Lead	ug/L	< 1	< 1	0	22
	2	Y	Manganese	ug/L	300	500	0	2000