

NOISE Monitoring Data - Monthly Summary								
Month	September							
EPL Licence	20079	Project		SOH VAPS				
EPL weblink	<a href="http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&amp;SYSUID=1&amp;LICID=20079">http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&amp;SYSUID=1&amp;LICID=20079</a>							
Specific EPL licence monitoring conditions for noise	Condition L3 - Noise limits Condition E2 - Out of Hours Works							
Monitoring location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laq (15min)	min value dB(A) for month	max value dB(A) for month	goals / targets dB(A)	Comment
1 Macquarie St	2	Attended	N	Laeq(15min)	45	45	50	
1 Macquarie St	2	Attended	N	Laeq(1min)	52	58	60	

**WATER Monitoring Data - Monthly Summary**

Month	September							
EPL Licence	20079	Project	SOH VAPS					
EPL weblink	<a href="http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&amp;SYSUID=1&amp;LICID=20079">http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31621&amp;SYSUID=1&amp;LICID=20079</a>							
Specific EPL licence monitoring conditions for water	Condition L2 - Concentration Limits Condition M2 - Requirement to monitor concentration of pollutants discharged							
Monitoring location	Number of times monitored during the month	Event based monitoring (Y/N)	Parameter measured	Units of measurement (mg/L, NTU, pH)	Minimum value for month	Maximum value for month	Allowable minimum limit	Allowable maximum limit
Water Treatment Plant Holding Tank	2	N	pH	pH Units	7.2	7.5	6.5	8.5
Water Treatment Plant Holding Tank	2	N	Total Suspended Solids	mg/L	<5	<5	0	50
Water Treatment Plant Holding Tank	2	N	Oil and Grease	mg/L	<5	<5	0	10
Water Treatment Plant Holding Tank	2	N	Copper	ug/L	1	7	0	10
Water Treatment Plant Holding Tank	2	N	Iron	ug/L	34	60	0	800
Water Treatment Plant Holding Tank	2	N	Lead	ug/L	<1	<1	0	22
Water Treatment Plant Holding Tank	2	N	Manganese	ug/L	20	26	0	2000