



VIBRATION Monitoring Data - Monthly Summary			
Month	Sep-17		
EPL Licence	20913	Project	Blacktown High Speed Crossover
EPL weblink			
monitoring conditions for vibration	Condition M4.1 - Noise & Vibration Condition M2.2 - Complaints		

Monitoring location	Number of times monitored during the month	Event based monitoring (Y/N)	Parameter eg. Peak particle velocity PPV, Airblast overpressure	Units of measurement (mm/s, dBL)	Minimum value for month	Maximum value for month	Allowable maximum limit	Percentile limit* (eg. 90th%ile)	percentile reporting period (1 year, 1 month, etc)
Alto Service Building, Jane St, Blacktown	1	N	PPV	mm/s	0.381	0.475	5	N/A	N/A

\*Percentile (in relation to a concentration limit of a sample): Means that percentage (e.g. 50%) of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time.