

WATER Monitoring Data - Monthly Summary

Month	Dec-17							
EPL Licence	20960	Project	New Grafton Correctional Facility					
EPL weblink	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=119193&SYSUID=1&LICID=20960							
Specific EPL licence monitoring conditions for water	Condition L2 - Concentration Limits Condition M2 - Requirement to monitor concentration of pollutants discharged							
Monitoring location	Number of times monitored during the month	Event based monitoring (Y/N)	Parameter measured	Units of measurement (mg/L, NTU, pH)	Minimum value for month	Maximum value for month	Allowable minimum limit	Allowable maximum limit
Sediment Basin 3	2	Y	pH	pH	7.2	7.4	6.5	8.5
			Total Suspended Solids	mg/L	40	42	NA	50
			Turbidity	NTU	35	40	NA	NA
Comments: NTU/turbidity continually monitored during discharge. 2 sets of laboratory samples taken for same event.								

