

WATER Monitoring Data - Monthly Summary

WATER Monitoring Data - Monthly Summary								
Month	Apr-18							
EPL Licence	20960	Project	New Grafton Correctional Facility					
EPL weblink	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=119193&SYSUID=1&LICID=20960							
Specific EPL licence monitoring conditions for water	Condition L2 - Concentration Limits Condition M2 - Requirement to monitor concentration of pollutants discharged							
Monitoring location	Number of times monitored during the month	Event based monitoring (Y/N)	Parameter measured	Units of measurement (mg/L, NTU, pH)	Minimum value for month	Maximum value for month	Allowable minimum limit	Allowable maximum limit
Waste Water Treatment Plant	1	Y	pH	pH	8.21	8.21	6.5	8.5
		Y	Total Suspended Solids	mg/L	39	39	NA	50
		Y	Turbidity	NTU	21	21	NA	67
Sediment Basin 1	1	Y	pH	pH	8.04	8.04	6.5	8.5
		Y	Total Suspended Solids	mg/L	38	38	NA	50
		Y	Turbidity	NTU	14.7	14.7	NA	67
Sediment Basin 2	1	Y	pH	pH	8.17	8.17	6.5	8.5
		Y	Total Suspended Solids	mg/L	38	38	NA	50
		Y	Turbidity	NTU	16.1	16.1	NA	67
Sediment Basin 3	1	Y	pH	pH	7.95	7.95	6.5	8.5
		Y	Total Suspended Solids	mg/L	36	36	NA	50
		Y	Turbidity	NTU	4.8	4.8	NA	67
Sediment Basin 4	1	Y	pH	pH	7.97	7.97	6.5	8.5
		Y	Total Suspended Solids	mg/L	49	49	NA	50
		Y	Turbidity	NTU	64	64	NA	67
Sediment Basin 5	1	Y	pH	pH	8.1	8.1	6.5	8.5
		Y	Total Suspended Solids	mg/L	36	36	NA	50
		Y	Turbidity	NTU	8.9	8.9	NA	67
Comments: NTU (turbidity) and pH continually monitored during discharge. TSS measurements extrapolated from approved TSS/NTU correlation spreadsheet.								

