

NOISE Monitoring Data - Monthly Summary

Month	Aug-18		
EPL Licence	20851	Project	Westconnex Enabling - Airport East Precinct
EPL weblink	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=110002&SYSUID=1&LICID=20851		
Specific EPL licence monitoring conditions for noise	Condition L2 - Noise limits	Condition L3 - Out of Hours Works	

Monitoring location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laq (15min)	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Observations
1295 Botany Road	1	Attended	Y	Leq	62.2	62.2	71	<p>Observations</p> <p>Continuous road traffic including heavy vehicles on Botany Road and Wentworth Avenue were audible.</p> <p>Construction activities included: excavator, light tower, water pump, traffic control.</p> <p>Dominant noise source from continuous road traffic.</p> <p>Alternative accommodation was offered during the period of works.</p> <p>No community complaints received.</p>