

**NOISE Monitoring Data - Monthly Summary**

Month	February 2019	
EPL Licence	20851	Project Westconnex Enabling - Airport East Precinct
EPL weblink	<a href="http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=110002&amp;SYSUID=1&amp;LICID=20851">http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=110002&amp;SYSUID=1&amp;LICID=20851</a>	
Specific EPL licence monitoring conditions for noise	Condition L2 - Noise limits	Condition L3 - Out of Hours Works

Monitoring location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laq (15min)	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Observations / Comments
1279 Botany Road	7	Attended	Y	Leq	59.9	71.6	75	Botany Road / Wentworth Avenue Intersection Shutdown works - dominant noise source - Removal of existing pavement and material load out - Placing and compacting road based material and asphalt - Traffic control system installation - Structural steel fixing and formwork Construction noise audible during traffic respite Alternative accommodation was offered during the period of works. No community noise complaint received
87 Hardie Street	6	Attended	Y	Leq	66.3	71.6	78	Botany Road / Wentworth Avenue Intersection Shutdown works - dominant noise source - Removal of existing pavement and material load out - Placing and compacting road based material and asphalt - Traffic control system installation - Structural steel fixing and formwork Construction noise audible during traffic respite Alternative accommodation was offered during the period of works. No community noise complaint received
1283 Botany Road	1	Attended	Y	Leq	62.8	62.8	65	Steel Barrier Installation works - Site noise inaudible, traffic was the dominant noise source No community noise complaint received