

NOISE Monitoring Data - Monthly Summary

Month	April 2019	
EPL Licence	20851	Project Westconnex Enabling - Airport East Precinct
EPL weblink	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=110002&SYSUID=1&LICID=20851	
Specific EPL licence monitoring conditions for noise	Condition L2 - Noise limits	Condition L3 - Out of Hours Works

Monitoring location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laq (15min)	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Observations / Comments
1297 Botany Road	4	Attended	Y	Leq	62.6	69.8	70	Steel fixing and concrete works at the underpass inaudible Crane moving materials west/east side of the rail bridge were inaudible. Laying pipe at Pit O/01 were intermittently audible. Alternative accommodation was offered during the period of works. Continuous road traffic - audible No community noise complaint received
87 Hardie Street	1	Attended	Y	Leq	65.5	65.5	65	Footpath works continued at Wentworth Compound Alternative accommodation was offered during the period of works. Continuous road traffic - audible No community noise complaint received
1281 Botany Road	2	Attended	Y	Leq	68.1	72.6	78	Vacuum truck in use, excavation and construction of temporary driveway of the foundry. Vacuum truck were intermittently audible. Traffic along Botany Road was continuous and dominant when passing at 3m from monitoring Alternative accommodation offered to relevant residents for these works No community noise complaint received