

NOISE Monitoring Data - Monthly Summary

Month	July 2019		
EPL Licence	20851	Project	Westconnex Enabling - Airport East Precinct
EPL weblink	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=110002&SYSUID=1&LICID=20851		
Specific EPL licence monitoring conditions for noise	Condition L2 - Noise limits		Condition L3 - Out of Hours Works

Monitoring location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laq (15min)	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Observations / Comments
1285 Botany Road	1	Attended	Y	Leq	65.3	65.3	78	Stormwater Line works and trenching were intermittently audible. Continuous road traffic was audible Alternative accommodation offered to relevant residents No community noise complaint received
1265 Botany Road	1	Attended	Y	Leq	68.3	68.3	76	Saw cutting was audible for a short period Continuous road traffic was audible Alternative accommodation offered to relevant residents for these works No community noise complaint received
87 Hardie Street	2	Attended	Y	Leq	63.1	68.1	70	Stormwater Line works continue including jackhammering and trenching were intermittently audible. Investigation works Continuous road traffic was audible Alternative accommodation offered to relevant residents for these works No community noise complaint received