

**NOISE Monitoring Data - Monthly Summary**

Month	<b>SEPTEMBER 2019</b>	
EPL Licence	<b>20851</b>	Project <b>Westconnex Enabling - Airport East Precinct</b>
EPL weblink	<a href="http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=110002&amp;SYSUID=1&amp;LICID=20851">http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=110002&amp;SYSUID=1&amp;LICID=20851</a>	
Specific EPL licence monitoring conditions for noise	<b>Condition L2 - Noise limits</b>	<b>Condition L3 - Out of Hours Works</b>

Monitoring location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laq (15min)	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Observations / Comments
1271 Botany Road	1	Attended	Y	Leq	59.2	59.2	84	Asphalt placement and line marking were intermittently audible. Kerb and footpath works include excavation, FRP and concrete were intermittently audible. Continuous road traffic was audible. Alternative accommodation offered to relevant residents No community noise complaint received
3 Wentworth Avenue	1	Attended	Y	Leq	72.2	72.2	79	Asphalt placement and line marking were intermittently audible. Continuous road traffic was audible. Alternative accommodation offered to relevant residents No community noise complaint received